

**Annexure C**

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE**

No. 11/2026

Dated: 17.06.2026

It is certified that an inspection team headed by ..... *Shine M* .....  
(Name of Officers with designation) from *Jr.HI* ..... PHED  
inspected the *Cherupushpa Central School, Ayoor* .....  
(Name & Address of the school) on *17/6/2026* ..... (date of inspection) and on the  
basis of Water Test Report (Attached) bearing no. *2026/9.13.01/KTR/509*  
dated *06.06.26* of *Quality Control Sub district Echruity, Kottayam* (PHED Lab)  
certified that the *Cherupushpa Central School, Ayoor* ..... (Name  
of school) has safe drinking water facilities for the students and members of staff of the  
institution. School is also maintains the hygienic sanitation condition in the school  
building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.  
This certificate is valid till *05.06.2027* .....



Signature with Seal: *[Signature]*

Name : *Shine M*

Designation : *Jr.HI*

Name & Address of the Office / Depart.....

To

*Cherupushpa Central School*  
*Ayoor*

(Name & Address of the Institution)

*For* **HEALTH INSPECTOR**  
**Primary Health Centre**  
**Edamulackal**

Note: The certificate is to be issued by authorized officer/PHED Lab/ Local bodies



No. 11/2026

GOVERNMENT OF KERALA

**HEALTH SERVICES DEPARTMENT**

**PRIMARY HEALTH CENTRE, EDAMULACKAL**

**SANITATION CERTIFICATE**

Certified that the sanitary facilities of ~~hotel / restaurant / coolbar / bakery / soda factory / cashew factory / chicken stall / fish stall / fruit stall / tea shop / auditorium / cattle farm / pig farm~~ <sup>School</sup> named CHERU PUSHPA CENTRAL

SCHOOL, AYOOR

owned by Sri / Smt. PRINCIPAL, CHERU PUSHPA

CENTRAL SCHOOL, AYOOR, KOLLAM

building no. XIII / 715 in EDAMULACKAL

Panchayat PUNNALOOR Taluk KOLLAM


dist., is adequate hygienic and environmentally good, the Certificate is issued for the limited purpose of producing at EDAMULACKAL Panchayat.

The validity period of this certificate is only from 29.05.2026

to 28.05.2027 or up to the date on which the public health authority find that the place is unhealthy or insanitary which ever is earlier.

Place: Edamulackal

Date: 29.05.2026



for  
Health Inspector  
Primary Health Centre  
Edamulackal



QUALITY CONTROL SUB DISTRICT LABORATORY  
KERALA WATER AUTHORITY  
VALAKAM P.O, KOTTARAKKARA, KOLLAM 691532  
(NABL Recognized Sub Divisional Level Government Drinking Water Testing Laboratory)

Test Report

Sl No.	Characteristics	Unit	Test Method	Maximum Acceptable limits as per IS 10500 - 2012	Result
1	Colour	(CU)	APHA 24th Edition: 2120 Colour Method B ( Platinum Cobalt Visual Comparison )	5	20
2	Odour	-	IS 3025 (Part 5): 2018	Agreeable	Agreeable
3	Taste	-	IS 3025 (Part 8) 2023	Agreeable	NT
4	Turbidity	(NTU)	IS 3025 (Part 10): 2023 Nephelometric Method	1	8.5
5	pH at 25 °C	-	IS 3025 (Part 11): 2022 Electrometric Method	6.5 to 8.5	7.27
6	Total Alkalinity ( as Ca CO <sub>3</sub> )	(mg/L)	IS 3025 (Part 23): 2023 Indicator Method	200	58
7	Total Dissolved Solids (TDS)	(mg/L)	IS 3025 (Part 16): 2023	500	125
8	Total Hardness (as CaCO <sub>3</sub> )	(mg/L)	IS 3025 (Part 21): 2009 EDTA Method	200	66
9	Calcium (as Ca)	(mg/L)	IS 3025 (Part 40): 2024 EDTA Method	75	21
10	Magnesium (as Mg)	(mg/L)	APHA 24th Edition 3500 Method B ( By calculation method)	30	< 5
11	Chloride (as Cl)	(mg/L)	IS 3025 (Part 32) : 1988 Argentometric Method	250	16

NB:- 1. The results stated above related only to the sample(s) submitted for testing. 2.This test certificate shall not be reproduced except in full without the written approval of the Laboratory.3.The results apply to the sample as received. 4. Sample will be retained only for 7 days after reporting the test results. 5. NT - Not Tested

*Dhanya*  
16/5/26

Authorized By  
Name: Dhanya V  
Sanitary Chemist  
KWA/QCSDL/KTR/R/19  
KOTTARAKKARA



QUALITY CONTROL SUB-DISTRICT LABORATORY  
KERALA WATER AUTHORITY  
VALAKAM P.O, KOTTARAKKARA, KOLLAM 691532

Test Report

Date Of issue : 16/05/2026

Report No - 2026/QCSDL/KTR/617	1. Date of Receipt : 15/05/2026
Customer Name & Address	2. Sampling done by : CUSTOMER
CHERUPUSHPA CENTRAL SCHOOL AYOOR AYOOR P O 691533 KOLLAM KERALA PH :860649631	3. Sample Code : 2026/QCSDL/KTR/617
	4. Source of Sample : WELL WATER
	5. Sample Description : DRINKING WATER
	6. Sample Quantity : 2 Litres
	7. Test Performing Dates From : 16/05/2026 To: 16/05/2026

Sl. No.	Characteristics	Unit	Test Method	Maximum Acceptable limits as per IS 10500 - 2012	Result
1	Electrical Conductivity at 25 °C	(micro mhos/cm)	IS 3025 (part 14) - 2013	—	199.1
2	Acidity	(mg/L)	IS 3025 (part 22) - 2024 Indicator Method	—	11
3	Sulphate (as SO <sub>4</sub> )	(mg/L)	IS 3025 (part 24/ Sec1) - 2022 Turbidity Method Using spectrophotometer	200	9.29
4	Fluoride (as F)	(mg/L)	APHA 24th Edition 4500 - F <sup>-</sup> D: SPADNS Method	1.0	0.02
5	Iron (as Fe)	(mg/L)	IS 3025 (part 53) - 2024 1,10 Phenanthroline Method	1.0	0.74
6	Nitrate (as NO <sub>3</sub> )	(mg/L)	APHA 24th Edition 4500 - NO <sub>3</sub> <sup>-</sup> B UV Spectrophotometric Screening Method	45	4.92

NB:- 1.The results stated above related only to the sample(s) submitted for testing. 2.This test certificate shall not be reproduced except in full without the written approval of the Laboratory. 3.The results apply to the sample as received. 4. Sample will be retained only for 7 days after reporting the test results.

*Dhanya V*  
16/5/26  
Authorized By  
Name: Dhanya V LAB  
Sanitary Chemist

KWA/QCSDL/KTR/R/19

Issue No. 01

\* End of Report \*  
Issue Date: 01.01.2022  
Page 1 of 1

Rev. No. 04

Rev.Date:26.06.25



QUALITY CONTROL SUB DISTRICT LABORATORY  
KERALA WATER AUTHORITY  
VALAKAM.P.O, KOTTARAKKARA, KOLLAM - 691 532  
☎ 0474 2918112 ✉ qcsdlktr@gmail.com

Test Report				
Report No: 2026/QCSDL/KTR/809		Date of Issue : 06/06/2026		
Customer Name & Address:		1. Date of Receipt :04/06/2026		
CHERUPUSHPA CENTRAL SCHOOL AYOOR P O 691533 KOLLAM PH :8606496361		2. Sampling done by : CUSTOMER		
		3. Sample Code : 2026/QCSDL/KTR/809		
		4. Source of Sample : WELL WATER		
		5. Sample Description : DRINKING WATER		
		6. Sample Quantity : 250 ml		
		7. Sample Condition : Good		
		8. Test Performing Dates From :04/06/2026 To:06/06/2026		
		SL. NO.	Characteristics	Test Method
1	Total Coliforms/ 100 ml	IS 15185 : 2016 (Reaffirmed 2021)	Shall not be detected/ 100 ml	ABSENT
2	<i>E. coli</i> /100 ml	IS 15185 : 2016 (Reaffirmed 2021)	Shall not be detected/ 100 ml	ABSENT
NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.A20:E23				
*End of Report*			 Authorized By Bacteriologist	
KWA/QCSDL/KTR/R/19		Issue No. 01	Issue Date: 10.01.2024	Rev. No. 01 Rev. Date: 01.01.2025
Page 1 of 1				

BACTERIOLOGIST  
QUALITY CONTROL SUB DISTRICT LAB  
KERALA WATER AUTHORITY  
KOTTARAKKARA